

**SCS Global Services** does hereby certify that an independent assessment has been conducted on behalf of:

# Flexco Floors

1401 E. 6th Street, Tuscumbia, AL, United States

For the following product(s):

## Vinyl Tile:

Crosswire™ Woven Vinyl Flooring



The product(s) meet(s) all of the necessary qualifications to be certified for the following claim(s):

## FloorScore®

Indoor Air Quality Certified to SCS-EC10.3-2014 v4.0

Conforms to the CDPH/EHLB Standard Method v1.2-2017 (California Section 01350), effective April 1, 2017, for the school classroom and private office parameters when modeled as Flooring.

Measured Concentration of Total Volatile Organic Compounds (TVOC): Less than/equal to 0.5 mg/m<sup>3</sup> (in compliance with CDPH/EHLB Standard Method v1.2-2017)

Registration # SCS-FS-02898

Valid from: October 26, 2020 to September 30, 2021

SCS Global Services is currently the only certification body approved by the Resilient Floor Covering Institute (RFCI) to provide FloorScore® product certification; certified products are only listed on the SCS Green Products Guide, <http://www.scsglobalservices.com/certified-green-products-guide>.



ISO/IEC 17065  
Product Certification Body  
#0821



A handwritten signature in black ink that reads "Stanley Mathuram".

Stanley Mathuram, PE, Vice President

SCS Global Services

2000 Powell Street, Ste. 600, Emeryville, CA 94608 USA